

# International Code Council Fire-Inspector-II Question Explanations, Latest Fire-Inspector-II Questions

---

## FIRE INSPECTOR II REAL QUESTIONS AND CORRECT ANSWERS LATEST UPDATE GRADED A+

How big are DOT labels? - ANSWER-4 inch square, on point  
Where is the primary DOT label? - ANSWER-On the left  
How many hazards can be on a DOT label? - ANSWER-several  
NFPA 704 - ANSWER-Hazardous Materials Marking System  
Placard: Blue means..... - ANSWER-Health Hazard  
Placard: Red means.... - ANSWER-Flammability Hazard  
Placard: Yellow means.... - ANSWER-Instability  
Placard: White means..... - ANSWER-Special Hazards  
5 Special Hazards - ANSWER-(1) Combustible Dust Fibers  
(2) Spraying/painting dip tanks  
(3) Compressed Gasses  
(4)Welding and cutting  
(5) Hazardous chemicals  
Article 15 of NFPA 70 - ANSWER-National Electric Code, Divided into 3 classes  
Class I Locations - ANSWER-Flammable gases and vapors exist under normal conditions  
Class I Division I Location - ANSWER-Ignitable conditions exist due to repairs or maintenance  
Class I Division II Location - ANSWER-Ignitable conditions produced or used but confined to closed containers or systems  
Class II Locations - ANSWER-Hazard is due to combustable dust

P.S. Free & New Fire-Inspector-II dumps are available on Google Drive shared by Pass4Test: <https://drive.google.com/open?id=1ENcp1r3pj-yTfAdlM49EFNQcgIN8hkQr>

We would like to provide our customers with different kinds of Fire-Inspector-II practice guide to learn, and help them accumulate knowledge and enhance their ability. Besides, we guarantee that the Fire-Inspector-II exam questions of all our users can be answered by professional personal in the shortest time with our Fire-Inspector-II Study Dumps. One more to mention, we can help you make full use of your sporadic time to absorb knowledge and information.

As for the points you may elapse or being frequently tested in the real exam, we give referent information, then involved them into our Fire-Inspector-II actual exam. Our experts expertise about Fire-Inspector-II training materials is unquestionable considering their long-time research and compile. I believe that no one can know the Fire-Inspector-II Exam Questions better than them. And they always keep a close eye on the changes of the content and displays of the Fire-Inspector-II study guide.

[>> International Code Council Fire-Inspector-II Question Explanations <<](#)

## Fire-Inspector-II Question Explanations 100% Pass | High Pass-Rate Fire-Inspector-II: 67 - Fire Inspector II Exam 100% Pass

If you have budget constraints, don't worry. Just check with Pass4Test to charge you less for all the 67 - Fire Inspector II Exam

(Fire-Inspector-II) exam dumps they provide you. Hence, if you are looking for a job change and want to get a good salary package, make sure that you start preparing for the International Code Council Fire-Inspector-II Certification Exam now. It is a good way to grab some of the brilliant opportunities by getting the 67 - Fire Inspector II Exam (Fire-Inspector-II) certification.

## International Code Council 67 - Fire Inspector II Exam Sample Questions (Q75-Q80):

### NEW QUESTION # 75

Battery-charging areas for industrial trucks shall be protected with portable fire extinguishers which have a minimum rating of

- A. 3-A:40-B:C
- B. 2-A:10-B:C
- C. 4-A:20-B:C
- D. 40-B:C

**Answer: D**

Explanation:

Battery-charging areas for industrial trucks (such as forklifts) present a fire hazard due to the potential for flammable hydrogen gas buildup and electrical malfunctions. To mitigate this risk, portable fire extinguishers with a minimum rating of 40-B:C are required.

Reference to Fire Inspector Documentation:

1. 2021 International Fire Code (IFC) - Section 309.5 (Fire Extinguishers for Battery-Charging Areas) IFC 309.5 states that battery-charging areas must have a portable fire extinguisher with a minimum rating of 40-B:C to handle potential electrical and flammable liquid fires.

The B rating covers flammable liquid fires (such as battery electrolyte leaks), while the C rating ensures it is safe for electrical fires.

2. NFPA 10 - Standard for Portable Fire Extinguishers (2022 Edition)

NFPA 10, Table 6.3.1.1 outlines that industrial battery-charging areas must have at least one extinguisher rated 40-B:C.

This ensures adequate fire suppression capability for both electrical and flammable liquid hazards.

Detailed Explanation of Answer Choices:

Option A (Incorrect): 4-A:20-B:C includes a higher A-rating (for ordinary combustibles), but 20-B:C is below the required 40-B:C.

Option B (Incorrect): 3-A:40-B:C exceeds the B:C requirements but adds an unnecessary A-rating, which is not specified in the code.

Option C (Incorrect): 2-A:10-B:C is insufficient, as it does not meet the 40-B:C minimum requirement.

Option D (Correct): 40-B:C is the correct and minimum required rating per IFC 309.5 and NFPA 10.

Thus, the correct and verified answer is: D. 40-B:C.

### NEW QUESTION # 76

A Type I handrail that is not circular shall have a minimum perimeter dimension of \_\_\_ inches.

- A. 1.25
- B. 0
- C. 1
- D. 6.25

**Answer: D**

Explanation:

According to the 2021 International Fire Code (IFC) and the International Building Code (IBC) Section 1014.3, handrails are categorized into Type I and Type II based on their shape and size requirements.

Type I handrails refer to those that are not circular in shape but still comply with graspability requirements.

IBC Section 1014.3.1 states that:

If a handrail is not circular, it must have a perimeter dimension between 4 inches (minimum) and 6.25 inches (maximum).

The cross-section of such a handrail should provide an adequate grasping surface.

### NEW QUESTION # 77

In a motion picture theatre, an audible announcement shall be made to notify the occupants of the location of exits to be used in the event of a fire or other emergency not more than how many minutes prior to the start of each program?

- A. 0
- **B. 1**
- C. 2
- D. 3

**Answer: B**

Explanation:

Exit Announcements in Motion Picture Theaters

According to the International Fire Code (IFC) 2021, Section 403.9.1.2, motion picture theaters must provide an audible announcement informing occupants of exit locations no more than 5 minutes prior to the start of each program.

This requirement ensures that audience members are aware of exit locations in case of an emergency, enhancing fire safety in crowded venues.

2. Verification of Other Options

Option B (10 minutes) - Exceeds the IFC maximum timeframe. Incorrect.

Option C (20 minutes) - Not specified in the IFC as a valid timeframe. Incorrect.

Option D (30 minutes) - Far beyond the required timeframe and would likely be ineffective. Incorrect.

Reference Sources:

International Fire Code (IFC) 2021 - Section 403.9.1.2 (Theater Exit Announcements) NFPA 101: Life Safety Code (Theater Occupancy Requirements) ICC Fire Inspector II Study Guide (2021)

**NEW QUESTION # 78**

Multiple smoke alarms installed within individual guest rooms of a hotel must comply with which of the following requirements?

- A. They must automatically sound a fire alarm throughout the hotel.
- **B. They must be interconnected so that one alarm will activate all alarms within the guest rooms.**
- C. They must initiate an automatic fire suppression or sprinkler system.
- D. Their batteries must be checked every six months.

**Answer: B**

Explanation:

Smoke alarm requirements for individual guest rooms in hotels are specified in the 2021 International Fire Code (IFC) Section 907.2.11.3 and NFPA 72 (National Fire Alarm and Signaling Code).

IFC 907.2.11.3 - Smoke Alarms in Group R-1 Occupancies (Hotels and Motels):

Requires smoke alarms in sleeping areas to be interconnected so that when one alarm is activated, it will trigger all alarms within the guest room or suite.

This ensures that occupants in different areas of the same guest room are alerted simultaneously to fire hazards.

Why Other Options Are Incorrect?

A). Their batteries must be checked every six months.

The IFC and NFPA 72 require smoke alarm batteries to be checked, but they do not mandate a six-month inspection schedule.

B). They must automatically sound a fire alarm throughout the hotel.

Smoke alarms within an individual guest room do not have to activate the entire hotel's fire alarm system.

C). They must initiate an automatic fire suppression or sprinkler system.

Smoke alarms are designed for early detection and warning, not for activating fire suppression systems.

# Correct answer: D. They must be interconnected so that one alarm will activate all alarms within the guest rooms.

**NEW QUESTION # 79**

Horizontal exits shall not comprise more than \_\_\_\_ of the required exits from any floor area in a Group I-2 occupancy.

- A. 1/3
- B. 3/4
- C. 2/3
- **D. 1/2**

**Answer: D**

Explanation:

For Group I-2 occupancies (such as hospitals, nursing homes, and similar healthcare facilities), horizontal exits are used to improve

fire safety by allowing occupants to move to a safer area without using stairs or elevators.

IFC 2021, Section 1026.1 (Horizontal Exits - General Requirements) states that:

Horizontal exits shall not comprise more than one-half (1/2) of the required exits from any floor area in a Group I-2 occupancy. This ensures that at least 50% of the required exits remain traditional vertical or exterior exits, maintaining a balance between horizontal and traditional egress routes.

# Correct answer: B. 1/2

## NEW QUESTION # 80

.....

Those who want to prepare for the IT certification exam are helpless. But they have to do it. So they have restless state of mind. However, With Pass4Test International Code Council Fire-Inspector-II Exam Training materials, the kind of mentality will disappear. With Pass4Test's International Code Council Fire-Inspector-II exam training materials, you can be brimming with confidence, and do not need to worry the exam. Of course, you can also face the exam with ease. This is not only psychological help, but more importantly, it allows you to pass the exam and to help you get a better tomorrow.

**Latest Fire-Inspector-II Questions:** <https://www.pass4test.com/Fire-Inspector-II.html>

International Code Council Fire-Inspector-II Question Explanations Or you can choose to change other exam subject, Choosing our Latest Fire-Inspector-II Questions - 67 - Fire Inspector II Exam training study material is a smart choice to your way to success and the best way to save your time and money, To further understand the merits and features of our Fire-Inspector-II practice engine, you should try it first, What's more, if you fail the Fire-Inspector-II test unfortunately, we will give you full refund without any hesitation.

When you drew for printing, you generated the Fire-Inspector-II same commands, Survey of Policy Languages, Or you can choose to change other exam subject, Choosing our 67 - Fire Inspector II Exam training study material Fire-Inspector-II Exam Pass4sure is a smart choice to your way to success and the best way to save your time and money.

## 2026 Fire-Inspector-II Question Explanations | Excellent 100% Free Latest 67 - Fire Inspector II Exam Questions

To further understand the merits and features of our Fire-Inspector-II Practice Engine, you should try it first, What's more, if you fail the Fire-Inspector-II test unfortunately, we will give you full refund without any hesitation.

People are engaged in modern society.

- Sample Fire-Inspector-II Questions  Fire-Inspector-II Practice Engine  Fire-Inspector-II Practice Engine  Open  [www.exam4labs.com](http://www.exam4labs.com)  and search for  Fire-Inspector-II   to download exam materials for free  Sample Fire-Inspector-II Questions Answers
- Reliable Fire-Inspector-II Test Pattern  Fire-Inspector-II Practice Engine  Dumps Fire-Inspector-II Download  Simply search for 「 Fire-Inspector-II 」 for free download on [ [www.pdfvce.com](http://www.pdfvce.com) ]  Fire-Inspector-II Latest Test Pdf
- Types Of International Code Council Fire-Inspector-II Exam Practice Test Questions  Download  Fire-Inspector-II   for free by simply searching on ▶ [www.examcollectionpass.com](http://www.examcollectionpass.com)◀  Real Fire-Inspector-II Dumps
- Fire-Inspector-II Lead2pass Review  Fire-Inspector-II 100% Exam Coverage  Fire-Inspector-II Exam Preview  Search for  Fire-Inspector-II  and download it for free on ▷ [www.pdfvce.com](http://www.pdfvce.com)◀ website  Fire-Inspector-II Latest Test Pdf
- Real Fire-Inspector-II Dumps  Braindumps Fire-Inspector-II Downloads  Fire-Inspector-II Exam Preview  Simply search for ( Fire-Inspector-II ) for free download on “ [www.torrentvce.com](http://www.torrentvce.com) ”  Reliable Fire-Inspector-II Test Vce
- Sample Fire-Inspector-II Questions Answers  Fire-Inspector-II Exam Preview  Fire-Inspector-II Practice Engine   [www.pdfvce.com](http://www.pdfvce.com)  is best website to obtain  Fire-Inspector-II  for free download  Sample Fire-Inspector-II Questions
- Fire-Inspector-II Latest Exam Online  Fire-Inspector-II Exam Fees  Fire-Inspector-II Exam Registration  Simply search for  Fire-Inspector-II  for free download on 《 [www.prepawayete.com](http://www.prepawayete.com) 》  Reliable Fire-Inspector-II Test Vce
- Fire-Inspector-II Pass4sure Questions - Fire-Inspector-II Vce Training - Fire-Inspector-II Free Demo  Search for 【 Fire-Inspector-II 】 on ↳ [www.pdfvce.com](http://www.pdfvce.com)  immediately to obtain a free download  Fire-Inspector-II Latest Test Pdf
- Reliable Fire-Inspector-II Test Pattern  New Braindumps Fire-Inspector-II Book  Real Fire-Inspector-II Dumps  Copy URL ( [www.examdiscuss.com](http://www.examdiscuss.com) ) open and search for [ Fire-Inspector-II ] to download for free  New

#### Braindumps Fire-Inspector-II Book

- Valid Fire-Inspector-II Exam Topics □ Fire-Inspector-II Latest Test Pdf □ Exam Fire-Inspector-II Tests □ Easily obtain free download of □ Fire-Inspector-II □ by searching on ↗ www.pdfvce.com □ □Practice Fire-Inspector-II Exam
- Types Of International Code Council Fire-Inspector-II Exam Practice Test Questions □ Search for ( Fire-Inspector-II ) on ↗ www.verifieddumps.com □ immediately to obtain a free download □Real Fire-Inspector-II Dumps
- bbs.t-firefly.com, erp.thetechgenacademy.com, www.stes.tyc.edu.tw, proverac.com, bbs.t-firefly.com, pct.edu.pk, mawada.om, discuz.szdawu.com, bbs.t-firefly.com, 121.40.19.218:89, Disposable vapes

P.S. Free & New Fire-Inspector-II dumps are available on Google Drive shared by Pass4Test: <https://drive.google.com/open?id=1ENcp1r3pJ-yTfFaDlM49EFNQcgIN8hkQr>