

# 67 - Fire Inspector II Exam Online Questions - Outstanding Practice To your Fire-Inspector-II Exam

---

## Fire Inspector 2 questions

What two physical properties of flammable liquids are used to classify them? -

**ANSWER**

A. Flash Point

B. Boiling point

The amount of heat given off by a particular substance during the combustion process is called? -

**ANSWER**

Heat of Combustion

The minimum temperature at which a liquid gives off sufficient vapor to form an ignitable mixture at the surface but not sufficient to sustain combustion is called its \_\_\_\_\_ -

**ANSWER**

Flash Point

Name the standard developed by the national Fire Protection Association to regulate the manufacture, storage, and handling of aerosol products. -

**ANSWER**

NFPA 30B

BONUS!!! Download part of SureTorrent Fire-Inspector-II dumps for free: <https://drive.google.com/open?id=1AzgOR1lko180oidImCVu0a1Q9wOLCj5m>

We have gained high appraisal for the high quality Fire-Inspector-II guide question and considerate serves. All content is well approved by experts who are arduous and hardworking to offer help. They eliminate banal knowledge and exam questions out of our Fire-Inspector-II real materials and add new and essential parts into them. And they also fully analyzed your needs of Fire-Inspector-II exam dumps all the time. Our after sales services are also considerate. If you get any questions with our Fire-Inspector-II guide question, all helps are available upon request. Once you place your order this time, you will enjoy and experience comfortable and convenient services immediately. Besides, we do not break promise that once you fail the Fire-Inspector-II Exam, we will make up to you and relieve you of any loss. Providing with related documents, and we will give your money back. We have been always trying to figure out how to provide warranty service if customers have questions with our Fire-Inspector-II real materials. So all operations are conducted to help you pass the exam with efficiency.

You may be also one of them, you may still struggling to find a high quality and high pass rate 67 - Fire Inspector II Exam study question to prepare for your exam. Your search will end here, because our study materials must meet your requirements. The Fire-Inspector-II torrent prep contains the real questions and simulation questions of various qualifying examinations. It is very worthy of study efficiently. Time is constant development, and proposition experts will set questions of Real Fire-Inspector-II Exam continuously according to the progress of the society change tendency of proposition, and consciously highlight the hot issues and policy changes.

## HOT Practice Fire-Inspector-II Test 100% Pass | Trustable Dumps 67 - Fire Inspector II Exam Questions Pass for sure

To help customers pass the International Code Council Fire-Inspector-II exam successfully. SureTorrent with 365 days updates. Valid Fire-Inspector-II Fire-Inspector-II exam dumps, exam cram and exam dumps demo. You can download these at a preferential price. We continually improve the versions of our Fire-Inspector-II Exam Guide so as to make them suit all learners with different learning levels and conditions.

### International Code Council 67 - Fire Inspector II Exam Sample Questions (Q61-Q66):

#### NEW QUESTION # 61

Given: A nonsprinklered commercial Type II-B building has a fire flow requirement of 7,000 gpm. If a sprinkler system is installed throughout the building, the new required fire flow is at least \_\_\_\_ gpm. (Assume that the new required fire flow is sufficient to meet the requirements of the sprinkler system.)

- A. 2,000
- B. 1,500
- C. 1,750
- D. 2,250

#### Answer: B

Explanation:

IFC Section 903.3.5 and Appendix B (Fire-Flow Requirements) allow a reduction in fire flow when sprinklers are installed. For a Type II-B building (noncombustible, unprotected), the base fire flow (7,000 gpm) reflects a large, unsprinklered structure (e.g., per Table B105.1(2)). With full sprinkler protection, IFC B105.2 permits a reduction to as low as 25% of the original flow or the sprinkler demand (whichever is greater), typically 1,500 gpm for commercial buildings per NFPA 13 standards, assuming adequate water supply. Options B, C, and D exceed this minimum without justification. Thus, A is correct.

#### NEW QUESTION # 62

In a motion picture theatre, an audible announcement shall be made to notify the occupants of the location of exits to be used in the event of a fire or other emergency not more than how many minutes prior to the start of each program?

- A. 0
- B. 1
- C. 2
- D. 3

#### Answer: C

Explanation:

Exit Announcements in Motion Picture Theaters

According to the International Fire Code (IFC) 2021, Section 403.9.1.2, motion picture theaters must provide an audible announcement informing occupants of exit locations no more than 5 minutes prior to the start of each program.

This requirement ensures that audience members are aware of exit locations in case of an emergency, enhancing fire safety in crowded venues.

#### 2. Verification of Other Options

Option B (10 minutes) - Exceeds the IFC maximum timeframe. Incorrect.

Option C (20 minutes) - Not specified in the IFC as a valid timeframe. Incorrect.

Option D (30 minutes) - Far beyond the required timeframe and would likely be ineffective. Incorrect.

#### Reference Sources:

International Fire Code (IFC) 2021 - Section 403.9.1.2 (Theater Exit Announcements) NFPA 101: Life Safety Code (Theater Occupancy Requirements) ICC Fire Inspector II Study Guide (2021)

### NEW QUESTION # 63

The occupant load of a building, or portion thereof, may be increased beyond the code's calculated minimum for the Group classification of the building, provided that all other requirements of the code are also met based on the modified number, and the occupant load does not exceed one occupant per \_\_\_ sq. ft.

- A. 0
- **B. 1**
- C. 2
- D. 3

#### Answer: B

Explanation:

Reference to Occupant Load Calculation:

The International Fire Code (IFC 2021), Section 1004.2 states that the calculated occupant load of a building may be increased if all other life safety provisions are met.

However, the occupant load cannot exceed one person per 5 square feet when increased beyond the standard calculations.

Fire Safety Considerations for Increased Occupant Load:

Increasing the occupant load requires ensuring:

Egress capacity (number and width of exits) meets the increased load.

Fire protection systems (sprinklers, alarms, etc.) are adequate for the new load.

Proper ventilation and sanitation facilities are maintained.

IFC 1004.2 and NFPA 101 both enforce the maximum limit of 1 occupant per 5 square feet in modified occupant load scenarios.

Clarification of Incorrect Answer Choices:

A: 3 sq. ft. # Incorrect

Too small for safe egress and occupant movement; the code does not allow such high density in general occupancies.

C: 7 sq. ft. # Incorrect

While some occupancies have higher space-per-occupant allowances, 5 sq. ft. is the maximum density permitted when increasing load.

D: 15 sq. ft. # Incorrect

15 sq. ft. per person is for lower-density assembly and business occupancies, not for maximum occupant load increases.

Conclusion:

The correct and verified answer is B (5 sq. ft. per occupant) as per IFC 1004.2 and NFPA 101, which govern occupant load increases in buildings.

### NEW QUESTION # 64

A local board of appeals may perform all of the following functions except:

- A. approve alternate materials and types of construction.
- B. render interpretations of the fire code.
- C. adopt rules and regulations for conducting its investigations.
- **D. waive requirements of the fire code.**

#### Answer: D

Explanation:

IFC Section 108 (Board of Appeals) outlines the board's role: it hears appeals on fire code official decisions (Section 108.1), can interpret the code (B), approve alternatives (C) per Section 104.9, and establish procedural rules (D) per Section 108.2. However, the board cannot "waive" code requirements outright (A)- it can only grant variances or approve alternatives that still meet the code's intent, not eliminate requirements entirely. Waiving implies nullification, which exceeds the board's authority, that power rests with the fire code official or legislative amendments. Thus, A is the exception.

### NEW QUESTION # 65

Atmospheric tanks with hazardous materials shall be equipped with a liquid-level limit control if they have a capacity which is greater than \_\_\_ gallons.

- A. 0

- B. 1
- **C. 2**
- D. 3

**Answer: C**

Explanation:

Reference to Liquid-Level Limit Control Requirements for Atmospheric Tanks:

According to The International Fire Code (IFC 2021), Section 5704.2.7.5, atmospheric tanks containing hazardous materials must be equipped with a liquid-level limit control if their capacity exceeds 500 gallons.

This requirement ensures that overfilling is prevented, reducing the risk of hazardous spills, leaks, and fire hazards.

Purpose of Liquid-Level Limit Controls:

These controls automatically shut off or alert operators when the liquid level reaches a predetermined limit.

They prevent tank overfill and reduce the risk of hazardous material release, which can cause fires, explosions, or environmental contamination.

Clarification of Incorrect Answer Choices:

A: 55 gallons # Incorrect

55-gallon drums are not subject to the same overfill protection requirements as large atmospheric tanks.

B: 100 gallons # Incorrect

Too low based on IFC 5704.2.7.5, which sets the requirement at 500 gallons.

C: 250 gallons # Incorrect

Some local regulations may require monitoring for tanks of this size, but IFC specifies 500 gallons as the mandatory threshold.

Conclusion:

The correct and verified answer is D (500 gallons) based on IFC 5704.2.7.5, ensuring proper overfill protection for atmospheric tanks containing hazardous materials.

**NEW QUESTION # 66**

.....

All these Fire-Inspector-II exam dumps formats contain real, updated, and error-free 67 - Fire Inspector II Exam (Fire-Inspector-II) exam questions that prepare you for the final Fire-Inspector-II exam. To give you an idea about the top features of Fire-Inspector-II Exam Dumps, a free demo download facility is being offered to 67 - Fire Inspector II Exam candidates. This free Fire-Inspector-II exam questions demo download facility is available in all three Fire-Inspector-II exam dumps formats.

**Dumps Fire-Inspector-II Questions:** <https://www.suretorrent.com/Fire-Inspector-II-exam-guide-torrent.html>

International Code Council Practice Fire-Inspector-II Test Come and you will be a winner, We have been trying to win clients' affection by our high quality Fire-Inspector-II learning materials: 67 - Fire Inspector II Exam and we realized it in reality, International Code Council Practice Fire-Inspector-II Test As most people like playing computer, even many IT workers depend on computer, studying on computer is becoming a new method, International Code Council Practice Fire-Inspector-II Test And there are 24/7 customer assisting in case you may encounter any problems like downloading.

Now imagine the effort that would be associated with making sure all Fire-Inspector-II these devices have the same time, The fastest and easiest way is to simply click the Search button on the toolbar or type Ctrl-F.

## **67 - Fire Inspector II Exam exam questions & Fire-Inspector-II torrent pdf & 67 - Fire Inspector II Exam actual dumps**

Come and you will be a winner, We have been trying to win clients' affection by our high quality Fire-Inspector-II Learning Materials: 67 - Fire Inspector II Exam and we realized it in reality.

As most people like playing computer, even many IT workers depend on computer, Fire-Inspector-II Exam Questions Vce studying on computer is becoming a new method, And there are 24/7 customer assisting in case you may encounter any problems like downloading.

The candidates can benefit themselves by using our Fire-Inspector-II test engine and get a lot of test questions like exercises and answers.

- Unique Features of [www.prep4pass.com](http://www.prep4pass.com)'s International Code Council Fire-Inspector-II Exam Questions (Desktop and Web-Based) □ ► [www.prep4pass.com](http://www.prep4pass.com) ▲ is best website to obtain ▶ Fire-Inspector-II □ for free download □ Latest

## Fire-Inspector-II Braindumps Files

- Fire-Inspector-II Flexible Learning Mode □ Reliable Fire-Inspector-II Exam Syllabus □ Valid Test Fire-Inspector-II Testking □ Download □ Fire-Inspector-II □ for free by simply entering □ [www.pdfvce.com](http://www.pdfvce.com) □ website □ Fire-Inspector-II Valid Test Simulator
- Valid Fire-Inspector-II Mock Exam □ Fire-Inspector-II Real Dump □ Fire-Inspector-II Latest Study Notes □ Open [www.itcerttest.com](http://www.itcerttest.com) and search for □ Fire-Inspector-II □ to download exam materials for free ↗ Valid Test Fire-Inspector-II Testking
- Latest Fire-Inspector-II Braindumps Files □ Valid Fire-Inspector-II Exam Notes □ Reliable Fire-Inspector-II Exam Syllabus □ Search for [\[ Fire-Inspector-II \]](http://www.pdfvce.com) and download it for free on ➤ [www.pdfvce.com](http://www.pdfvce.com) □ website □ Fire-Inspector-II Valid Test Simulator
- Practice Fire-Inspector-II Tests □ New Fire-Inspector-II Test Braindumps □ Valid Fire-Inspector-II Mock Exam □ Search for [\[ Fire-Inspector-II \]](http://www.pdfvce.com) and download it for free on [www.testsdumps.com](http://www.testsdumps.com) website □ Fire-Inspector-II Latest Study Notes
- Fire-Inspector-II Test Discount □ Latest Fire-Inspector-II Braindumps Files □ Practice Fire-Inspector-II Tests □ Enter ➤ [www.pdfvce.com](http://www.pdfvce.com) □ and search for ➡ Fire-Inspector-II □ □ □ to download for free □ Fire-Inspector-II Real Dump
- New Fire-Inspector-II Test Braindumps □ Reliable Fire-Inspector-II Exam Syllabus □ Reliable Fire-Inspector-II Exam Syllabus □ Go to website ➡ [www.actual4labs.com](http://www.actual4labs.com) □ open and search for ⚡ Fire-Inspector-II ⚡ ⚡ □ to download for free □ Fire-Inspector-II Valid Test Simulator
- Fire-Inspector-II Dumps Guide: 67 - Fire Inspector II Exam - Fire-Inspector-II Actual Test - Fire-Inspector-II Exam Torrent □ Enter [\[ www.pdfvce.com \]](http://www.pdfvce.com) and search for [\[ Fire-Inspector-II \]](http://www.pdfvce.com) to download for free □ Fire-Inspector-II Reliable Source
- 2025 International Code Council Fire-Inspector-II: 67 - Fire Inspector II Exam – Trustable Practice Test □ Search for [\[ Fire-Inspector-II \]](http://www.pdfvce.com) and easily obtain a free download on “[www.pdfdumps.com](http://www.pdfdumps.com)” □ Fire-Inspector-II Latest Study Notes
- Fire-Inspector-II Reliable Source □ Latest Fire-Inspector-II Braindumps Files □ Valid Fire-Inspector-II Mock Exam □ □ Enter □ [www.pdfvce.com](http://www.pdfvce.com) □ and search for { Fire-Inspector-II } to download for free □ Valid Fire-Inspector-II Mock Exam
- All Three [www.exam4pdf.com](http://www.exam4pdf.com) International Code Council Fire-Inspector-II Exam Dumps Format is Ready for Download □ □ Download [\[ Fire-Inspector-II \]](http://www.exam4pdf.com) for free by simply searching on □ [www.exam4pdf.com](http://www.exam4pdf.com) □ □ Valid Fire-Inspector-II Mock Exam
- [myportal.utt.edu.tt](http://myportal.utt.edu.tt), [www.scribd.com](http://www.scribd.com), [zbx244.ampblogs.com](http://zbx244.ampblogs.com), [daotao.wisebusiness.edu.vn](http://daotao.wisebusiness.edu.vn), [nualkale.blogocial.com](http://nualkale.blogocial.com), [myportal.utt.edu.tt](http://myportal.utt.edu.tt), [tutorxpert.com.au](http://tutorxpert.com.au), [Disposable vapes](http://Disposable vapes)

BTW, DOWNLOAD part of SureTorrent Fire-Inspector-II dumps from Cloud Storage: <https://drive.google.com/open?id=1AzgOR1ko180oidImCVu0a1Q9wOLCj5m>