

# Fire-Inspector-II Reliable Test Test - Fire-Inspector-II Exam Online

---

## Fire Inspector Practice Exam Questions and Answers Already Graded A

Which of the following is NOT considered to be a model code organization?

- A. National Fire Protection Association
- B. National Fire Academy
- C. International Code Council
- D. American Society of Mechanical Engineers ✓✓B. National Fire Academy

A prescriptive code does which of the following?

- A. List the specific details the installation or construction must meet
- B. Requires equipment to be installed for protection against a hazard
- C. Is intereted locally
- D. Is a national standard ✓✓A. List the specific details the installation or construction must meet

What type of tanker typically transport 6,000 to 10,000 gallons of flammable and combustible materials?

P.S. Free 2026 International Code Council Fire-Inspector-II dumps are available on Google Drive shared by ValidTorrent: [https://drive.google.com/open?id=1Y-YZuPxkwkIY8AFPx9xTBoqNysx8sI7\\_](https://drive.google.com/open?id=1Y-YZuPxkwkIY8AFPx9xTBoqNysx8sI7_)

Different with other similar education platforms on the internet, the 67 - Fire Inspector II Exam guide torrent has a high hit rate, in the past, according to data from the students' learning to use the Fire-Inspector-II test torrent, 99% of these students can pass the qualification test and acquire the qualification of their yearning, this powerfully shows that the information provided by the Fire-Inspector-II study tool suit every key points perfectly, targeted training students a series of patterns and problem solving related routines, and let students answer up to similar topic. It may say, the Fire-Inspector-II Test Torrent can let users in a short time, accurately grasp the proposition trend of each year, doing all effects in the process of the difficulties in the hot, user's weak link and targeted training, and exercise the user's solving problem ability, eventually achieve the objectives of the pass 67 - Fire Inspector II Exam qualification test.

If you feel that you always suffer from procrastination and cannot make full use of your spare time, maybe our Fire-Inspector-II study materials can help you solve your problem. We are willing to recommend you to try the Fire-Inspector-II practice guide from our company. Our Fire-Inspector-II learning questions are in high quality and efficiency test tools for all people. You can just try our three different versions of our Fire-Inspector-II training quiz, you will find that you can study at anytime and anyplace.

>> **Fire-Inspector-II Reliable Test Test** <<

## Fire-Inspector-II Exam Online & Valid Dumps Fire-Inspector-II Files

Our Fire-Inspector-II test braindumps are carefully developed by experts in various fields, and the quality is trustworthy. What's more, after you purchase our products, we will update our Fire-Inspector-II exam questions according to the new changes and then send them to you in time to ensure the comprehensiveness of learning materials. We also have data to prove that 99% of those who use our Fire-Inspector-II Latest Exam torrent to prepare for the exam can successfully pass the exam and get International Code Council certification. So if you are preparing to take the test, you can rely on our learning materials. You will also be the next beneficiary. After you get International Code Council certification, you can get boosted and high salary to enjoy a good life.

### International Code Council 67 - Fire Inspector II Exam Sample Questions (Q72-Q77):

#### NEW QUESTION # 72

Newly upholstered furniture may be required to resist ignition by cigarettes in common areas in which of the following nonsprinklered occupancies?

- A. Office spaces
- B. Libraries in Group E
- C. Group A-1
- D. **Group I-2**

**Answer: D**

Explanation:

In nonsprinklered occupancies, newly upholstered furniture in common areas must resist ignition by cigarettes primarily in Group I-2 occupancies (such as hospitals, nursing homes, and care facilities). This requirement reduces the risk of fire ignition in environments where occupants may have limited mobility and are unable to evacuate quickly.

Reference to Fire Inspector Documentation:

1. 2021 International Fire Code (IFC) - Section 805.2 (Ignition Resistance of Upholstered Furniture and Mattresses) IFC 805.2 specifies that nonsprinklered Group I-2 occupancies must have upholstered furniture that resists ignition by cigarettes because these settings involve vulnerable populations who may need assistance in an emergency.

2. NFPA 101 - Life Safety Code (2021 Edition) - Section 10.3.2 (Fire-Retardant Upholstered Furniture) NFPA 101, Section 10.3.2 aligns with the IFC in requiring that furniture in health care facilities (Group I-2) must meet fire resistance standards to prevent ignition from cigarettes and other sources.

Detailed Explanation of Answer Choices:

Option A (Correct): Group I-2 (hospitals, nursing homes, and assisted living facilities) is required to have cigarette-ignition-resistant upholstered furniture in nonsprinklered common areas.

Option B (Incorrect): Group A-1 (theaters and performing arts venues) does not have this requirement, as seating arrangements are different and typically involve fire-resistant materials.

Option C (Incorrect): Office spaces (Business Occupancies, Group B) do not require ignition-resistant furniture under fire code regulations.

Option D (Incorrect): Libraries in Group E (Educational Occupancies) are not required to have this furniture unless otherwise specified by local codes.

Thus, the correct and verified answer is: A. Group I-2

#### NEW QUESTION # 73

Given: A health club contains a 1,000-sq. ft. exercise room.

Based on the square footage, what is the calculated occupant load allowed for this exercise room?

- A. 0
- B. 1
- **C. 2**
- D. 3

**Answer: C**

Explanation:

The occupant load of a space is determined using the 2021 International Building Code (IBC), Table 1004.5 - Maximum Floor Area Per Occupant.

**IBC Table 1004.5 - Occupant Load Factor for Exercise Rooms:**

The occupant load factor for an exercise room is 1 person per 20 square feet.

Given that the exercise room is 1,000 sq. ft.:

1,000 sq. ft.  $\div$  20 sq. ft. per person = 50 occupants

Why Other Options Are Incorrect?

A). 10 - Would require a 100 sq. ft. per person load factor, which is not applicable for exercise rooms.

B). 20 - Incorrect calculation; using the correct load factor, the actual number is 50.

C). 30 - Also incorrect based on the proper load factor.

# Correct answer: D. 50

**NEW QUESTION # 74**

The maximum quantity of liquefied petroleum gas (LP-gas) in containers stored by a dealer awaiting resale, and are at one location in a building that is not accessible to the public, is \_\_\_ lb. water capacity.

- A. 2,500
- B. 1,000
- **C. 2,000**
- D. 0

**Answer: C**

Explanation:

The storage of liquefied petroleum gas (LP-gas) in containers by dealers awaiting resale is regulated by the 2021 International Fire Code (IFC), Section 6109 - Storage of Portable LP-Gas Containers.

IFC 6109.11 - Storage Within Buildings Not Accessible to the Public:

"Storage of LP-gas containers in buildings that are not accessible to the public shall be limited to a maximum aggregate quantity of 2,000 pounds water capacity at one location." Why Other Options Are Incorrect?

A). 735 lb. - Too low; the maximum allowed is 2,000 lb.

B). 1,000 lb. - Incorrect; IFC allows up to 2,000 lb.

D). 2,500 lb. - Exceeds the 2,000 lb. maximum permitted storage quantity.

# Correct answer: C. 2,000 lb.

**NEW QUESTION # 75**

The use of listed portable unvented oil-burning heating appliances is prohibited in which of the following occupancies?

- **A. Groups A, E, I, R-1, R-2, R-3, and R-4 occupancies**
- B. Groups R-3, M, S-1, and S-2 occupancies
- C. Groups B and F occupancies
- D. Groups A and B occupancies

**Answer: A**

Explanation:

Restrictions on Portable Unvented Oil-Burning Heaters

According to the International Fire Code (IFC) 2021, Section 603.4, the use of listed portable unvented oil-burning heating appliances is prohibited in certain occupancies where fire and life safety risks are higher.

The prohibited occupancies include:

Group A (Assembly) - Includes theaters, churches, stadiums, etc.

Group E (Educational) - Includes schools, daycares, etc.

Group I (Institutional) - Includes hospitals, nursing homes, jails, etc.

Group R-1, R-2, R-3, R-4 (Residential Occupancies) - Includes hotels, apartments, assisted living, and residential care facilities.

2. Why These Occupancies Are Prohibited

Portable unvented oil-burning heaters pose a significant fire hazard and can produce harmful gases such as carbon monoxide.

In high-occupancy and residential buildings, improper use or malfunction of these heaters could lead to fatal fire or health hazards.

Ventilation concerns in institutional and assembly settings make these heaters particularly dangerous.

3. Verification of Other Options

Option A (Groups A and B occupancies) - Incorrect, as Group B (Business) is not explicitly prohibited from using these heaters.

Option B (Groups B and F occupancies) - Incorrect, as Group F (Factory/Industrial) is not listed under IFC

603.4 as a prohibited occupancy.

Option C (Groups R-3, M, S-1, and S-2 occupancies) - Incorrect, as M (Mercantile) and S (Storage) occupancies are not listed as restricted areas.

Reference Sources:

International Fire Code (IFC) 2021 - Section 603.4 (Portable Unvented Oil-Burning Heating Appliances) NFPA 1: Fire Code (Portable Heater Use Restrictions in Various Occupancies)

## NEW QUESTION # 76

Quantities of flammable liquid storage in a control area of an Industrial Occupancy may be doubled when:

- A. the control area is provided with exhaust ventilation in accordance with fire code requirements.
- B. the control area exceeds 50,000 sq. ft.
- C. permission is granted by the chief.
- D. the building is protected with automatic sprinklers.

**Answer: D**

Explanation:

Flammable Liquid Storage Limits in Control Areas

According to the International Fire Code (IFC) 2021, Section 5003.1.1 and Table 5003.1.1(1), the allowable quantity of flammable liquids stored in a control area can be doubled if the building is equipped with an automatic sprinkler system that complies with NFPA 13.

### 2. Why Automatic Sprinklers Allow Increased Storage

A sprinkler system significantly reduces fire risk by suppressing flames early, thus allowing greater quantities of hazardous materials to be safely stored.

IFC and NFPA 30 (Flammable and Combustible Liquids Code) specify that sprinkler-protected buildings can have up to twice the standard storage limits.

### 3. Verification of Other Options

Option A (permission is granted by the chief) - Incorrect, as storage limits are regulated by the fire code, not discretionary approval from the fire chief.

Option B (the control area exceeds 50,000 sq. ft.) - Incorrect, as floor area does not automatically allow for increased storage unless fire protection systems are in place.

Option D (the control area is provided with exhaust ventilation) - Incorrect, because ventilation is required for hazardous material control but does not impact storage limits like sprinklers do.

Reference Sources:

International Fire Code (IFC) 2021 - Section 5003.1.1 & Table 5003.1.1(1) (Control Area Storage Limits for Flammable Liquids) NFPA 30: Flammable and Combustible Liquids Code (Sprinkler-Adjusted Storage Quantities) ICC Fire Inspector II Study Guide (2021) Thus, the correct and verified answer is: C. the building is protected with automatic sprinklers. # Reference: IFC 2021, Table 5003.1.1(1), Section 5003.8.3.5.

## NEW QUESTION # 77

.....

Do you have bought the International Code Council pdf version for your preparation? If not, hurry up to choose our Fire-Inspector-II pdf torrent. Our Fire-Inspector-II pdf study material is based on the Fire-Inspector-II real exam scenarios covering all the exam objectives. You will find it is very helpful and precise in the subject matter since all the Fire-Inspector-II Exam contents is regularly updated and has been checked and verified by our professional experts. Fire-Inspector-II will help you to strengthen your technical knowledge and allow you pass at your first try.

**Fire-Inspector-II Exam Online:** <https://www.validtorrent.com/Fire-Inspector-II-valid-exam-torrent.html>

The Fire-Inspector-II study materials of our company is the study tool which best suits these people who long to pass the Fire-Inspector-II exam and get the related certification, Make sure that you're utilizing refreshed practice questions to upgrade your skills so it is possible to maintain a strategic distance from each of the problems that you're confronting concerning the Fire-Inspector-II Exam Online - 67 - Fire Inspector II Exam exam, And as long as you try our Fire-Inspector-II practice questions, you will love it!

Working with Docklings, This static route can then be redistributed and advertised by a routing protocol, The Fire-Inspector-II study materials of our company is the study tool which best suits these people who long to pass the Fire-Inspector-II Exam and get the related certification.

## **Pass Guaranteed 2026 International Code Council Fire-Inspector-II: 67 - Fire Inspector II Exam Useful Reliable Test Test**

Make sure that you're utilizing refreshed practice questions to upgrade your Fire-Inspector-II skills so it is possible to maintain a strategic distance from each of the problems that you're confronting concerning the 67 - Fire Inspector II Exam exam.

And as long as you try our Fire-Inspector-II practice questions, you will love it. If you are a college student, you can learn and use online resources through the student learning platform over the Fire-Inspector-II study materials.

Besides, the explanation after each Fire-Inspector-II question is compiled by professionals who make it easy to understand and remember.

What's more, part of that ValidTorrent Fire-Inspector-II dumps now are free: <https://drive.google.com/open?id=1Y-YZuPxkwkIY8AFPx9xTBoqNysx8sI7>