

Free PDF Quiz NICET - ITFAS-Level-1–Professional Fresh Dumps

Nicet level 1 Study Guide Questions and complete solutions

When testing a water level supervisory switch serving a pressure tank a signal shall indicate if the water level _____ from the required level

(NFPA 72, Table 14.4.3.2 17 (j) (4) - ✓✓ rises or falls over 3 inches

If combination audible/visible appliances are installed the location of the installed appliance shall be determined by the requirements of _____.

(Nfpa 72 18.4.8.1) - ✓✓ the visible appliance

What is the maximum number of 12 gauge THHN wires that can be installed in 1" EMT?

(Nec Annex C tables) - ✓✓ 26

Two resistors are connected in parallel. R1 = 300 Ohms, R2 = 300 Ohms. What is their equivalent resistance? - ✓✓ 150 ohms

A Room is 200' long and 150' wide and the 8' high ceiling is smooth and flat. A spot type heat detector has been selected that is listed for a 50' maximum spacing between detectors. According to NFPA 72 how many detectors will be needed to protect this room?

$200 / 50 \times 150 / 50 = - \checkmark \checkmark 12$

According to NFPA 72 the minimum number of restorable fixed temperature spot type heat detectors that must be tested during each annual test is?

(NFPA 72 14.4.4.5.1) - ✓✓ Two detectors or more on each initiating device circuit

According to NFPA 72 how many spot type heat detectors are required for a space that is 80' long and 55 floor wide with a smooth 10' ceiling? the detector is listed for a maximum space between detectors of 30' - ✓✓ 6

BTW, DOWNLOAD part of ActualVCE ITFAS-Level-1 dumps from Cloud Storage: https://drive.google.com/open?id=18MsXM6_3ILB8FYTqRqIVdqW0evuODFGd

So it is very necessary for you to try your best to get the ITFAS-Level-1 certification in a short time. If you are determined to get the certification, our ITFAS-Level-1 question torrent is willing to give you a hand; because the ITFAS-Level-1 study materials from our company will be the best study tool for you to get the certification. Now I am going to introduce our ITFAS-Level-1 Exam Question to you in detail, please read our introduction carefully, we can make sure that you will benefit a lot from it. If you are interest in our ITFAS-Level-1 exam material, you can buy it right now.

ActualVCE also offers a demo of the NICET ITFAS-Level-1 exam product which is absolutely free. Up to 1 year of free Inspection and Testing of Fire Alarm Systems Level I Exam (ITFAS-Level-1) questions updates are also available if in any case the sections of the NICET ITFAS-Level-1 actual test changes after your purchase. Lastly, we also offer a full refund guarantee according to terms and conditions if you do not get success in the NICET Inspection and Testing of Fire Alarm Systems Level I Exam Certification Exam after using our ITFAS-Level-1 product. These offers by ActualVCE save your time and money. Buy Inspection and Testing of Fire Alarm Systems Level I Exam (ITFAS-Level-1) practice material today.

>> Fresh ITFAS-Level-1 Dumps <<

NICET ITFAS-Level-1 Test Simulator Free | ITFAS-Level-1 Exam Preview

The passing rate of our ITFAS-Level-1 study materials is 99% and the hit rate is also high. Our study materials are selected strictly based on the real ITFAS-Level-1 exam. Our expert team guarantees that each answer and question is useful and valuable. We also update frequently to guarantee that the client can get more learning ITFAS-Level-1 resources and follow the trend of the times. So if you use our study materials you will pass the test with high success probability.

NICET Inspection and Testing of Fire Alarm Systems Level I Exam Sample Questions (Q16-Q21):

NEW QUESTION # 16

Which of the following is the inspection frequency of the candela rating of visible appliances?

- A. Initial acceptance and if a malfunction occurs
- B. Initial acceptance and quarterly
- C. Initial acceptance and no further inspections
- D. Initial acceptance and semiannually

Answer: A

Explanation:

Candela ratings are visually confirmed during initial acceptance. Further inspection is required only if a device malfunction occurs or are acceptance tests performed.

NFPA 72 (2022), Section 18.5.5.7:

"The candela rating shall be verified at initial acceptance and when there is reason to believe the device is not operating properly."

NEW QUESTION # 17

Which of the following options is required while conducting annual testing of an audiovisual device?

- A. Confirm sound level based on design
- B. Verify proper setting of candela rating
- C. Verify proper operation
- D. Confirm voice intelligibility

Answer: C

Explanation:

When performing annual testing of notification appliances such as strobes or horns, NFPA 72 mandates functional testing- which means checking that they operate correctly when activated.

NFPA 72 (2022), Table 14.4.3.2 - Testing Frequencies and Methods:

Under "Notification Appliances," the required method for both audible and visible devices is:

"Functional test - verify proper operation."

While things like sound levels and candela settings are verified during acceptance testing or design review, the annual requirement is simply to verify that they work.

Correct answer: C. Verify proper operation

NEW QUESTION # 18

After successful completion of an inspection, who shall be responsible for maintaining the permanent records?

- A. Owner
- B. AHJ
- C. Alarm contractor
- D. Fire marshal

Answer: A

Explanation:

NFPA 72 assigns the responsibility for maintaining inspection and testing records to the owner or their designated representative. This ensures records are available when needed by the AHJ or for future inspections.

NFPA 72 (2022), Section 14.6.1:

"The property or building owner or the owner's designated representative shall be responsible for the inspection, testing, and

maintenance of the system and for maintaining the records." This responsibility cannot be offloaded to the contractor or fire marshal unless formally designated by the owner.

Correct answer: D. Owner

NEW QUESTION # 19

Which three of the following test methods are used to ensure that the smoke detectors are within their sensitivity range? (Choose three.)

- A. AHJ approved calibrated test
- B. Manufacturer's calibrated sensitivity test instrument
- C. Test approved by the engineer
- D. Listed control equipment arranged for testing

Answer: A,B,D

Explanation:

To verify that smoke detectors are operating within their listed sensitivity range, NFPA 72 provides three approved testing methods. These ensure proper functionality and compliance with safety requirements.

NFPA 72 (2022), Section 14.4.4.3.1:

"Sensitivity shall be checked using any of the following methods:

(1) Calibrated test method approved by the authority having jurisdiction (2) Listed control equipment arranged for the purpose (3) Calibrated sensitivity test instrument of the smoke detector manufacturer" The option "test approved by the engineer" is not listed among the approved sensitivity test methods in NFPA 72, and therefore is not acceptable for compliance.

NEW QUESTION # 20

At which height above the floor is the sound level measured for public and private mode audible devices?

- A. 8.0 feet (2.4 meters)
- B. 7.5 feet (2.3 meters)
- C. 2.5 feet (0.7 meter)
- D. 5.0 feet (1.5 meters)

Answer: D

Explanation:

Sound level readings for fire alarm audible notification appliances must be taken at a consistent, standardized height to ensure compliance with required dBA levels.

NFPA 72 (2022), Section 18.4.6.1:

"Sound pressure level measurements shall be taken with a sound level meter positioned 5 ft (1.5 m) above the floor in the area required to be served by the system" This applies to both public mode (e.g., schools, offices) and private mode (e.g., staff-only zones like hospitals).

Correct answer: B. 5.0 feet (1.5 meters)

NEW QUESTION # 21

.....

According to a recent report, those who own more than one skill certificate are easier to be promoted by their boss. To be out of the ordinary and seek an ideal life, we must master an extra skill to get high scores and win the match in the workplace. Our ITFAS-Level-1 exam question can help make your dream come true. What's more, you can have a visit of our website that provides you more detailed information about the ITFAS-Level-1 Guide Torrent. Just have a try our ITFAS-Level-1 exam questions, then you will know that you will be able to pass the ITFAS-Level-1 exam.

ITFAS-Level-1 Test Simulator Free: <https://www.actualvce.com/NICET/ITFAS-Level-1-valid-vce-dumps.html>

If you think it is very difficult for you to pass exams, our ITFAS-Level-1 valid exam cram PDF can help you to achieve your goal, NICET Fresh ITFAS-Level-1 Dumps Our questions and answers are based on the real exam and conform to the popular trend in the industry, The pass rate is 98%, and pass guarantee and money back guarantee if you fail to pass the exam. Besides we also

have the free demo for you to try, before buying, it will help you to have a general idea of the ITFAS-Level-1 exam dumps. Particularly, advertisement agencies and the media houses have enough room for ITFAS-Level-1 certified.

All the questions are edited according to the analysis of data and summarized from the previous test, which can ensure the high hit rate, You can get NICET ITFAS-Level-1 complete as long as you enter ActualVCE website.

NICET Fresh ITFAS-Level-1 Dumps Exam 100% Pass | ITFAS-Level-1: Inspection and Testing of Fire Alarm Systems Level I Exam

If you think it is very difficult for you to pass exams, our ITFAS-Level-1 valid exam cram PDF can help you to achieve your goal. Our questions and answers are based on the real exam and conform to the popular trend in the industry.

The pass rate is 98%, and pass guarantee and money back guarantee if you fail to pass the exam. Besides we also have the free demo for you to try, before buying, it will help you to have a general idea of the ITFAS-Level-1 exam dumps.

Particularly, advertisement agencies and the media houses have enough room for ITFAS-Level-1 certified, The app version supports tablet computer, mobile phone and iPad.

BTW, DOWNLOAD part of ActualVCE ITFAS-Level-1 dumps from Cloud Storage: https://drive.google.com/open?id=18MsXM6_3ILB8FYTqRqIVdqW0evuODFGd