

New NICET ITFAS-Level-1 Study Materials - Valid ITFAS-Level-1 Test Answers

Nicet level 1 Study Guide questions and answers 100% pass

When testing a water level supervisory switch serving a pressure tank a signal shall indicate if the water level _____ from the required level

(NFPA 72, Table 14.4.3.2 17 (j) (4) - Answer-rises or falls over 3 inches

If combination audible/visible appliances are installed the location of the installed appliance shall be determined by the requirements of _____.

(Nfpa 72 18.4.8.1) - Answer-the visible appliance

What is the maximum number of 12 gauge THHN wires that can be installed in 1" EMT?

(Nec Annex C tables) - Answer-26

Two resistors are connected in parallel. R1 = 300 Ohms, R2 = 300 Ohms. What is their equivalent resistance? - Answer-150 ohms

A Room is 200' long and 150' wide and the 8' high ceiling is smooth and flat. A spot type heat detector has been selected that is listed for a 50' maximum spacing between detectors. According to NFPA 72 how many detectors will be needed to protect this room?

P.S. Free 2026 NICET ITFAS-Level-1 dumps are available on Google Drive shared by PDFTorrent:
https://drive.google.com/open?id=11KrFZynHD2sM_ljBugLlc7Lrpe81rwcM

In today's world, the Inspection and Testing of Fire Alarm Systems Level I Exam (ITFAS-Level-1) certification exam has become increasingly popular, providing professionals with the opportunity to upskill and stay competitive in the tech industry. At PDFTorrent, we understand the importance of obtaining the NICET ITFAS-Level-1 Certification in the NICET sector, where technological advancements constantly evolving.

It is a popular belief that only professional experts can be the leading one to do some adept job. And similarly, only high quality and high accuracy ITFAS-Level-1 Exam Questions like ours can give you confidence and reliable backup to get the certificate smoothly because our experts have extracted the most frequent-tested points for your reference. Good practice materials like our Inspection and Testing of Fire Alarm Systems Level I Exam study question can educate exam candidates with the most knowledge. Do not make your decisions now will be a pity for good.

>> New NICET ITFAS-Level-1 Study Materials <<

Valid ITFAS-Level-1 Test Answers | ITFAS-Level-1 Latest Exam Materials

Our ITFAS-Level-1 exam materials are flexible and changeable, and the service provided by our company is quite specific. Our

ITFAS-Level-1 test questions have been following the pace of digitalization, constantly refurbishing, and adding new things. I hope you can feel the ITFAS-Level-1 exam prep sincerely serve customers. We also attach great importance to the opinions of our customers. As long as you make reasonable recommendations for our ITFAS-Level-1 test material, we will give you free updates to the system's benefits. We have always advocated customer first. If you use our learning materials to achieve your goals, we will be honored. ITFAS-Level-1 exam prep look forward to meeting you.

NICET Inspection and Testing of Fire Alarm Systems Level I Exam Sample Questions (Q68-Q73):

NEW QUESTION # 68

Inspection records for all systems shall be kept for which length of time?

- A. Until the next test and 1 year
- B. Until AHJ reviews records and 1 year
- C. 6 months
- D. 5 years

Answer: A

Explanation:

NFPA 72 outlines the retention period for records of inspections and testing in Section 14.6.3.1. These records are important for verification during audits or when reviewing system maintenance history.

NFPA 72 (2022), Section 14.6.3.1:

"Records shall be retained for a period of one year after the next test and until the next test is performed." This means records must be kept until the next test happens and for 1 year after that, not just a fixed calendar period.

Correct answer: D. Until the next test and 1 year

NEW QUESTION # 69

When testing a room temperature switch, below what temperature does the off-normal signal occur?

- A. 40 °F (4.4 °C)
- B. 45 °F (7.2 °C)
- C. 50 °F (10.0 °C)
- D. 32 °F (0.0 °C)

Answer: A

Explanation:

Room temperature switches are used to detect freezing conditions in environments such as sprinkler valve rooms. An off-normal (supervisory) condition is triggered if the temperature drops below 40 °F (4.4 °C).

NFPA 72 (2022), Section A.17.16.1.1:

"Low-temperature supervisory signals shall be initiated when the temperature falls below 40 °F (4.4 °C) unless otherwise specified." This signal helps prevent system damage or failure due to freezing.

Correct answer: B. 40 °F (4.4 °C)

NEW QUESTION # 70

After successful completion of an inspection, who shall be responsible for maintaining the permanent records?

- A. Fire marshal
- B. Owner
- C. AHJ
- D. Alarm contractor

Answer: B

Explanation:

NFPA 72 assigns the responsibility for maintaining inspection and testing records to the owner or their designated representative. This ensures records are available when needed by the AHJ or for future inspections.

NFPA 72 (2022), Section 14.6.1:

"The property or building owner or the owner's designated representative shall be responsible for the inspection, testing, and maintenance of the system and for maintaining the records." This responsibility cannot be offloaded to the contractor or fire marshal unless formally designated by the owner.

Correct answer: D. Owner

NEW QUESTION # 71

Which two of the following are needed to perform a periodic test of a projected beam type smoke detector? (Choose two.)

- A. Using an optical filter
- B. Using a listed test switch
- C. Introducing smoke
- D. Blocking the transmitter

Answer: A,B

Explanation:

Projected beam smoke detectors are tested not with actual smoke, but by simulating obscuration using listed tools such as a test switch or optical filter.

NFPA 72 (2022), Section 14.4.2.2.6.2:

"Projected beam-type smoke detectors shall be tested by introducing an obscuration in the beam path using an optical density filter or a method approved by the manufacturer." Some systems include listed test switches for functional checks without disrupting alignment.

Correct answer: Using a listed test switch, Using an optical filter

NEW QUESTION # 72

A single open fault, in a Class A pathway, shall result in the annunciation of which of the following signals?

- A. Supervisory
- B. Trouble
- C. Pre-alarm
- D. Alarm

Answer: B

Explanation:

In a Class A fire alarm circuit, a single open condition does not affect communication but must still be annunciated as a trouble signal.

NFPA 72 (2022), Section 12.3.1.1.4:

"A single open condition on a Class A pathway shall result in a trouble signal." This maintains system operation while alerting of a wiring fault.

Correct answer: D. Trouble

NEW QUESTION # 73

.....

All these three PDFTorrent ITFAS-Level-1 exam questions formats contain valid, updated, and real Inspection and Testing of Fire Alarm Systems Level I Exam exam questions. The NICET ITFAS-Level-1 exam questions offered by the PDFTorrent will assist you in ITFAS-Level-1 Exam Preparation and boost your confidence to pass the final NICET ITFAS-Level-1 exam easily.

Valid ITFAS-Level-1 Test Answers: <https://www.pdftorrent.com/ITFAS-Level-1-exam-prep-dumps.html>

What's more, with the time passing by, many experts have been tenaciously exploring the means of achieving a higher pass rate of ITFAS-Level-1 practice materials, which will undoubtedly stimulate all of our staff to be in concerted efforts to obtain a pass rate of one hundred percent that has never occurred before. With the simulation test, all of our customers will get accustomed to the ITFAS-Level-1 exam easily, and get rid of bad habits, which may influence your performance in the real ITFAS-Level-1 exam.

Soft version are downloaded and installed on Windows operating system and Java New ITFAS-Level-1 Study Materials environment, Software Engineering Forces Us to Forget the Individual, What's more, with the time passing by, many experts have been tenaciously exploring the means of achieving a higher pass rate of ITFAS-Level-1 practice materials, which will undoubtedly

stimulate all of our staff to be in concerted efforts to obtain a pass rate of one hundred percent that has never occurred before.

NICET New ITFAS-Level-1 Study Materials: Inspection and Testing of Fire Alarm Systems Level I Exam - PDFTorrent Assist you Clear Exam

With the simulation test, all of our customers will get accustomed to the ITFAS-Level-1 exam easily, and get rid of bad habits, which may influence your performance in the real ITFAS-Level-1 exam.

Unlike the general questions and answers in the same field, our ITFAS-Level-1 Inspection and Testing of Fire Alarm Systems Level I Exam exam simulator make it possible for customers to participate in the exams after 20 or 30 hours' studying.

We eliminated the filler and simplified the Inspection and Testing of Fire Alarm Systems Level I Exam exam ITFAS-Level-1 Latest Exam Materials preparation process so you can ace the NICET exam on your first try, Your exam results will help you prove this!

BTW, DOWNLOAD part of PDFTorrent ITFAS-Level-1 dumps from Cloud Storage: https://drive.google.com/open?id=11KrFZynHD2sM_ljBugLlc7Lrpe81rwcM